

BULK SITE INSPECTION FORM

SOLD TO: _____ SHIP TO: _____

TENKOZ PRODUCT SHIPMENT QUANTITY REQUESTED SHIP DATE

RETAILER EPA ESTABLISHMENT NUMBER: _____

BULK EQUIPMENT CHECKLIST

Tank Size: _____ gallons AASA Bulk Tank Number _____

Tank Type: _____ poly _____ mild steel _____ stainless steel _____ other

MINIMUM SITE REQUIREMENTS

	<u>Yes</u>	<u>No</u>
1. Tank is free of stress cracks, weakened welds, punctures and other signs of aging or structural defects.	___	___
2. Tank capacity allows required 5% headspace.	___	___
3. Tank sits on a solid level base.	___	___
4. All steel plumbing.	___	___
5. Tank outlet has a stainless steel locking ball valve.	___	___
6. Tank is vented to prevent entry of water, dirt, and other contaminants.	___	___
7. Tank opening allows for inside inspection and cleaning.	___	___
8. a) Tank is empty, clean and dry.	___	___
b) Tank currently contains same product.	___	___
9. a) Exterior site gauge is present.	___	___
b) If an exterior site gauge is present, it is equipped with a shut-off valve.	___	___
10. Product can be recirculated from bottom to top (flowables only).	___	___
11. The site has a contingency plan for spills and fires.	___	___
12. Tank is diked and any outlet, if present, is permanently plugged with concrete. Type of dike: Concrete____, Steel____, Block____, Other____	___	___
13. Tank is plumbed separate from other herbicides, fertilizer or water.	___	___
14. Tank's profile is kept within dike walls.	___	___
15. Equipment is present to handle a minor spill and it's clean up. Equipment includes protective clothing, boots, respirator, goggles, rubber gloves, and absorbent material.	___	___
16. A security system is in effect at the site.	___	___
17. Does bulk site have a rinsate system? (must be "yes" if state requires)	___	___
18. Roof over dike.	___	___
19. Building around entire facility.	___	___
20. Tank is secured from possible floating or tipping.	___	___
21. Tank is plumbed to avoid any possibilities of cross contamination.	___	___
22. Tank is plumbed so it can be filled from the bottom.	___	___

I have inspected this tank and it is ready to receive delivery of product and has complied with all state and/or local requirements.

Signature _____ Signature _____ Date _____
Distributor Agent Retailer